

Supported Protocols for SoftPLC Gateway Models

As of 6/1/22

Protocol	NeoPAC (SN2-x)	Smart (SMS4-x)	Hardbook (HB)
ASCII (COMGENIUS)	Y	Y	Y
A-B Data Highway Plus (DH+)	Y Requires SPO-BH	Y Requires SPO-BH	Y ¹ requires HB1/HB2/HB4- + ICO-PKTXI-PKTXD
A-B DF1 Ethernet (CSP/PCCC) Master (Client)	Y	Y	Y
A-B DF1 Ethernet (CSP/PCCC) Slave (Server)	Y	Y	Y
A-B DF1 Full Duplex Peer-Peer	Y	Y	Y
A-B DF1 Half Duplex Slave	Y	Y	Y
A-B RIO Master (Scanner)	Y Requires SPO-BH	Y Requires SPO-BH	n/a
A-B RIO Slave (Adapter)	Y Requires SPO-BH	Y Requires SPO-BH	n/a
EthernetIP Master (Scanner)	Y	Y	Y
EthernetIP Slave (Adapter)	Y	Y	Y
Modbus Serial Master	Y Requires SPO-485	Y	Y
Modbus Serial Slave	Y Requires SPO-485	Y	Y
Modbus TCP/UDP Master (Client)	Y	Y	Y
Modbus TCP/UDP Slave (Server)	Y	Y	Y
CAN/J1939	n/a	Y Model SM2S-x only requires SM-CAN6	n/a
Enron ModbusTCP Master	Y	Y	Y

Notes

- 1 The interface card for this driver is obsolete. Call for availability.